HAWAIIAN CEMENT

B20260622
CERTIFICATE NUMBER

June 22, 2026
DATE

Laboratory Test Certificate

MASONRY CEMENT/PLASTIC CEMENT/MORTAR CEMENT
(ULTRAMORTAR)

			Type S	Type M
Compressive Strength	**Value**		**Limit**	**Limit**
7 Days	**4620 psi**		**1300 psi**	**1800 psi**
	(31.8 MPa)		**(9.0 MPa)**	**(12.4 MPa)**
28 Days	**5200 psi**		**2100 psi**	**2900 psi**
	(35.8 MPa)		**(14.5 MPa)**	**(20.0 MPa)**
Fineness - Retained on No. 325, %	**2.1 %**		**24% Max**	**24% Max**
Air Content of mortar, %	**14.2 %**		**8.0 Min**	**8.0 Min**
Masonry, C91			**19.0 Max**	**19.0 Max**
Plastic, C1328			**20.0 Max**	**20.0 Max**
Mortar, C1329			**19.0 Max**	**19.0 Max**
Time of Set, Gilmore Method				
Initial Set, minutes	**240**	**min.**	**90 Min**	**90 Min**
Final Set, minutes	**315**	**min.**	**1000 Max**	**1000 Max**
Autoclave Expansion, %	**0.02 %**		**1.0 Max**	**1.0 Max**

We certify that the above described cement, at the time of shipment, meets the requirements of ASTM C91-18 Type "M" Masonry Cement, C1328-23 Type "M" Plastic Cement and C1329-25 Type "S" Mortar Cement.

Cement Division

Office: 99-1300 Halawa Valley Street
Aiea, HI 96701
Phone: (808) 532-3400

Daniel K. Paaaina III
Cement Chemist